

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 2280-2140:0100 Page 1 of 1

CATEGORY: 2280 -- COATING MATERIALS (FLAME SPREAD)

LISTEE: Fire Retardant Coatings of Texas 1150 Blue Mound Road West #403, Haslet, TX 76052
Contact: David Paulo (817) 710-5233 Fax (817) 306-9414
Email: david@frctexas.com

DESIGN: FX Lumber Guard and FX Lumberguard XT Retardant Coatings are one coat application applied at 300-250 square feet per gallon. Sprayed, rolled, or brush applied on dimensional Southern Yellow Pine lumber. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Class A:
Flame Spread 15
Smoke Developed 115

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product name and SFM label.

APPROVAL: Listed as a fire retardant coating for dimensional Southern Yellow Pine and other similar species. Interior use only. Refer to listee's Installation Instruction Manual for details.

10-10-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 10, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division