



Most Widely Accepted and Trusted

ICC-ES Listing Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

ESL-1087

Reissued 10/2017

This listing is subject to renewal 10/2018.

DIVISION: 09 00 00—FINISHES

SECTION: 09 96 43—FIRE-RETARDANT COATINGS

REPORT HOLDER:

FIRE RETARDANT COATINGS OF TEXAS, LLC

**1150 BLUE MOUND ROAD WEST, SUITE 403
HASLET, TEXAS 76052**

EVALUATION SUBJECT:

FX LUMBER GUARD / FX LUMBER GUARD XT FIRE-RETARDANT COATINGS



Look for the trusted marks of Conformity!

“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”



A Subsidiary of

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



ICC-ES Listing Report

ESL-1087

Reissued October 2017

This listing is subject to renewal October 2018.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 09 00 00—FINISHES
Section: 09 96 43—Fire-Retardant Coatings

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: FX LUMBER GUARD / FX LUMBER GUARD XT FIRE-RETARDANT COATINGS

Listee: FIRE RETARDANT COATINGS OF TEXAS, LLC
1150 BLUE MOUND ROAD WEST, SUITE 403
HASLET, TEXAS 76052
(817) 710-5233
www.frctexas.com

Evaluation: FX Lumber Guard / FX Lumber Guard XT Fire-Retardant Coatings, when applied to unfinished Southern Yellow Pine dimensional lumber and Southern Yellow Pine plywood at a minimum coverage rate of 300 square feet per gallon (7.36 m²/L), were evaluated when tested to the following standards:

- ASTM E84-09 and ASTM E84-07, Standard Test Method for Surface Burning Characteristics of Building Materials, ASTM International.
- UL 723-2008 and UL 723-03 (revisions through May 2005), Standard for Test for Surface Burning Characteristics for Building Materials, Underwriters Laboratories, Inc.

Findings: FX Lumber Guard / FX Lumber Guard XT Fire-Retardant Coatings, when applied to unfinished Southern Yellow Pine dimensional lumber and Southern Yellow Pine plywood at a minimum coverage rate of 300 square feet per gallon (7.36 m²/L), have a flame-spread index and a smoke-developed index as specified in Table 1 below based on testing in accordance with ASTM E84 / UL 723.

TABLE 1—FLAME SPREAD INDEX AND SMOKE DEVELOPED INDEX

SUBSTRATE COATED WITH FX LUMBER GUARD OR FX LUMBER GUARD XT	FLAME-SPREAD INDEX (FSI)	SMOKE-DEVELOPED INDEX (SDI)
SOUTHERN YELLOW PINE - DIMENSIONAL LUMBER	25	130
SOUTHERN YELLOW PINE - PLYWOOD	10	125

Identification: Containers of FX Lumber Guard and FX Lumber Guard XT fire retardant coatings are identified by the label bearing the manufacturer's name (Fire Retardant Coatings of Texas, LLC) and address, the product name, the date of the manufacture, shelf life, the manufacturer's instructions for application, the ICC-ES Listing Report number (ESL-1087), and when applicable, the ICC-ES Listing Mark.

Installation: The product must be installed in accordance with the Fire Retardant Coatings of Texas, LLC's published installation instructions and applicable codes.

Conditions of listing:

1. The listing report addresses only conformance with the standard noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing report applies only to the materials tested and as submitted for review by ICC-ES.
4. FX Lumber Guard and FX Lumber Guard XT fire retardant coatings are manufactured in Haslet, Texas, under a quality control program with inspections by ICC-ES.